



## 8900 Series Submittal Data

**JOB NAME:** \_\_\_\_\_

**LOCATION:** \_\_\_\_\_

**ARCH/ENGR:** \_\_\_\_\_

**CONTRACTOR:** \_\_\_\_\_

**MODEL NO:** \_\_\_\_\_

**TYPE GAS:** \_\_\_\_\_

**BTU INPUT/OUTPUT:** \_\_\_\_\_

### ADDITIONAL INFORMATION:

#### Standard Features

- 81% Efficiency
- Cast Iron Headers (Boiler)
- Bronze Headers (Water Heater)
- Structural Steel Frame
- Front Mount 24V Controls
- Threaded Connections
- Field Reversible Headers
- 2-Pass Finned Copper Tube Heat Exchanger
- Slide Out Heat Exchanger
- Slide Out Burner Tray
- ASME Pressure Relief Valve Mounted
- 2 ½" Interlocking Combustion Chamber
- Integral Drafthood
- Thermometer
- Temperature/Pressure Gauge
- 115/24V Transformer
- Indoor Installation
- Flow Switch Mounted and Wired
- IID, Spark Ignition Control
- Manual Reset High Limit
- Operating Aquastat
- Pump Delay Relay 9 Amp
- Leak Test Valves
- FM/CSD-1 Gas Train Compliant
- On/Off Firing

#### Optional Equipment

- 2 Stage Firing
- 4 Stage Firing (Spark Ignition Only)
- Propane Gas
- Cupronickel Heat Exchanger
- Wired & Mounted Flange
- 5' Pump Pigtail
- Alarm Bell
- Flame Failure Dry Contact
- Main Flame Status Relay
- Enable/Disable Relay 24V
- Enable/Disable Relay 120V
- Low Gas Pressure Switch
- High Gas Pressure Switch
- Left Hand Gas Connection
- Right Hand Water Connection
- Dual Flue (840 – 1900)
- Power Venter Wiring
- 1PH Pump Contactor
- 3PH Pump Contactor (shipped loose)
- Keyboard Display Module
- Light Package
- Remote/Local Switch
- Sidewall Vent Kit
- Vent Termination Hood
- Pump

#### Gas Trains

- CSD-1 Code
- Kentucky Code