

## Input/Output Variables (Read/Write)

Name	SNVT Type/Index	Description	Valid Values/Range												
nviHeatDemand	SNVT_switch 100	Heat Demand/Request. Setting the state member of this variable will put the boiler in heating mode.	<table border="1"> <thead> <tr> <th>state</th> <th>value</th> <th>Interpretation</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>0</td> <td>no heat demand</td> </tr> <tr> <td>0</td> <td>&gt;0</td> <td>heat demand</td> </tr> <tr> <td>1</td> <td>any</td> <td>heat demand</td> </tr> </tbody> </table>	state	value	Interpretation	0	0	no heat demand	0	>0	heat demand	1	any	heat demand
state	value	Interpretation													
0	0	no heat demand													
0	>0	heat demand													
1	any	heat demand													
nviSetpointTimer	SNVT_count 101	<p>System Setpoint Timer</p> <p>The system setpoint timer is a BMS failsafe feature. This countdown timer should be periodically reloaded with a timeout value (in seconds). If the timer reaches zero, the control assumes that the BMS is no longer operating and the local setpoint (saved on the control) is reloaded. This is a failsafe feature used to help safeguard the system in case of BMS failure.</p> <p>When any (1) Read/Write variable is timer is written, if the SetpointTimer is less than 60, it is automatically reloaded with 60.</p> <p>(1) In control firmware versions &lt; 3.38, the BMS has to write the SystemSetpoint to automatically reload the SetpointTimer.</p>	0 – 65535 seconds												
nviSetpoint	SNVT_temp_p 102	System Setpoint (see <i>nviSetpointTimer</i> )	4.5 – 104.4 °C (40 - 220 °F)												
nviOARResetEnable	SNVT_switch 103	Enables/Disables outdoor air reset mode.	<table border="1"> <thead> <tr> <th>state</th> <th>value</th> <th>interpretation</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>0</td> <td>disabled</td> </tr> <tr> <td>0</td> <td>&gt;0</td> <td>enabled</td> </tr> <tr> <td>1</td> <td>any</td> <td>enabled</td> </tr> </tbody> </table>	state	value	interpretation	0	0	disabled	0	>0	enabled	1	any	enabled
state	value	interpretation													
0	0	disabled													
0	>0	enabled													
1	any	enabled													
nviOARSetpoint	SNVT_temp_p 104	Outdoor air reset setpoint. Temperature at which boiler shuts down.	4.5 – 37.8 °C (40 – 100 °F)												
nviOARHiWtrTemp	SNVT_temp_p 105	Boiler water temperature setpoint when outdoor air temperature is at the high outdoor air temperature setpoint ( <i>nviOARHiAirTemp</i> ).	15.6 – 87.8 °C (60 – 190 °F)												
nviOARHiAirTemp	SNVT_temp_p 106	High outdoor air temperature setpoint.	10 – 32.2 °C (50 – 90 °F)												
nviOARLoWtrTemp	SNVT_temp_p 107	Header/Supply temperature setpoint when outdoor air temperature is at the low outdoor air temperature setpoint ( <i>nviOARLoAirTemp</i> ).	21.1 – 104.4 °C (70 – 220 °F)												

Name	SNVT Type/Index	Description	Valid Values/Range												
nviOARLoAirTemp	SNVT_temp_p 108	Low outdoor air temperature setpoint.	-37.2 – 4.4 °C (-35 – 40 °F)												
nviSetMonth	SNVT_count 109	Set real time clock – month ( <i>see nviSetClock</i> )	0 (January) – 11 (December)												
nviSetDay	SNVT_count 110	Set real time clock – day ( <i>see nviSetClock</i> )	1 – 31												
nviSetYear	SNVT_count 111	Set real time clock – year ( <i>see nviSetClock</i> )	0 – 99												
nviSetHour	SNVT_count 112	Set real time clock – hour ( <i>see nviSetClock</i> )	0 – 23												
nviSetMinute	SNVT_count 113	Set real time clock – minute ( <i>see nviSetClock</i> )	0 – 59												
nviSetSecond	SNVT_count 114	Set real time clock – second ( <i>see nviSetClock</i> )	0 – 59												
nviSetWeekday	SNVT_count 115	Set real time clock – weekday ( <i>see nviSetClock</i> )	1 (Monday) – 7 (Sunday)												
nviSetClock	SNVT_switch 116	Set (write) the real time clock.  To write the real time clock, the system variables (nviSetMonth, nviSetMonth, nviSetDay, nviSetYear, nviSetHour, nviSetMinute, nviSetSecond, nviSetWeekday) must first be loaded with the correct date and time. Then, a 1 must be written to the state portion of this system variable to write the new date and time to the system clock.	<table border="1"> <thead> <tr> <th>state</th> <th>value</th> <th>interpretation</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>0</td> <td>---</td> </tr> <tr> <td>0</td> <td>&gt;0</td> <td>set the clock</td> </tr> <tr> <td>1</td> <td>any</td> <td>set the clock</td> </tr> </tbody> </table>	state	value	interpretation	0	0	---	0	>0	set the clock	1	any	set the clock
state	value	interpretation													
0	0	---													
0	>0	set the clock													
1	any	set the clock													
<b>--- The following are supported bridge configuration versions 2.50 and greater ---                      (HeatNet control firmware version 3.38 or greater required)</b>															
nviDHWSetpoint	SNVT_temp_p 117	DHW Setpoint	4.4 – 93.3 °C (40 – 200 °F)												

## Input Variables (Read Only)

Name	SNVT Type/Index	Description	Valid Values/Range
nvoBoilersOn	SNVT_count 200	The number of boilers currently running.	0 – 16
nvoModulation	SNVT_lev_cont_f 201	Current system (target) modulation level. This is the modulation level that the system is trying to run at to meet the heating demand.	0 – 100 %
nvoHeaderTemp	SNVT_temp_p 202	Header / System temperature.	0 – 121.1 °C (32 – 250 °F)
nvoSupplyTemp	SNVT_temp_p 203	Supply temperature.	0 – 121.1 °C (32 – 250 °F)
nvoReturnTemp	SNVT_temp_p 204	Return temperature.	0 – 121.1 °C (32 – 250 °F)
nvoOutsideTemp	SNVT_temp_p 205	Outside air temperature.	-40 – 121.1 °C (-40 – 250 °F)
nvoSpare1	SNVT_count 206	Raw A/D value from spare 1 input.	-32768 to 32767
nvoSpare2	SNVT_count 207	Raw A/D value from spare 2 input.	-32768 to 32767
nvoMonth	SNVT_count 208	Real time clock month.	0 (January) – 11 (December)
nvoDay	SNVT_count 209	Real time clock day.	1 – 31
nvoYear	SNVT_count 210	Real time clock year.	0 – 99
nvoHour	SNVT_count 211	Real time clock hour.	0 – 23
nvoMinute	SNVT_count 212	Real time clock minute.	0 – 59
nvoSecond	SNVT_count 213	Real time clock second.	0 – 59
nvoWeekday	SNVT_count 214	Real time clock weekday.	1 (Monday) - 7 (Sunday)

Name	SNVT Type/Index	Description	Valid Values/Range
nvoClock	SNVT_time_stamp 215	Real time clock date and time.	0 – 11
nvoBlr01Status1 ... nvoBlr16Status1	SNVT_state  300 302 304 ... 328 330  (Even Indices)	Boiler status flags #1 (boilers 1 – 16). These bits indicate the state of the 24VAC interlocks, ignition circuit, and various other conditions.	See Appendix A for more information.
nvoBlr01Status2 ... nvoBlr16Status2	SNVT_state  301 303 305 ... 329 331  (Odd Indices)	Boiler status flags #2 (boilers 1 – 16). These bits indicate the state of the ignition circuit, sensors, and various other conditions.	See Appendix A for more information.
nvoBlr01Status3 ... nvoBlr16Status3	SNVT_state  400 ... 415	Boiler stage control input flags. These bits indicate the state of the stage control inputs.	See Appendix A for more information.
nvoBlr01Runtime ... nvoBlr16Runtime	SNVT_reg_val  500 ... 515	The total number of minutes that the boiler has been running (with the current control board).	0 – 35791394 minutes
nvoBlr01Cycles ... nvoBlr16Cycles	SNVT_reg_val  600 ... 615	The total number of boiler cycles (with the current control board).	0 – 2147483647 cycles
<b>--- The following are supported bridge configuration versions 2.20 and greater ---</b>			
nvoBlr01Supply ... nvoBlr16Supply	SNVT_temp_p  616 ... 631	The boiler supply (outlet) temperature.	0 – 121.1 °C (32 – 250 °F)

Name	SNVT Type/Index	Description	Valid Values/Range
nvoBlr01Return ... nvoBlr16Return	SNVT_temp_p  632 ... 647	The boiler return (inlet) temperature.	0 – 121.1 °C (32 – 250 °F)
<b>--- The following are supported bridge configuration versions 2.50 and greater --- (HeatNet control firmware version 3.38 or greater required)</b>			
nvoBlr01Status4 ... nvoBlr16Status4	SNVT_state  648 ... 663	Boiler (1 – 16) status4 flags. These bits indicate the state of various boiler statuses.	See Appendix A for more information.
nvoBlr01DHW ... nvoBlr16DHW	SNVT_temp_p  664 ... 679	Boiler (1 – 16) DHW temperature (if available). See Boiler Status4 to determine if the sensor is present.	0 – 121.1 °C (32 – 250 °F)
nvoBlr01Modulate ... nvoBlr16Modulate	SNVT_lev_cont_f  680 ... 695	The running (“display”) modulation. This is typically the actual running modulation except under special circumstances when the boiler is running in a self-protection mode (Op. Limit, ½ Fire Rate, etc.)	0 – 100 %
nvoOpSetpoint	SNVT_temp_p  696	This is the current operating or active setpoint. It may be:  1) The normal heating setpoint. 2) The DHW setpoint if running in DHW mode. 3) A calculated setpoint if running in Outdoor Air Reset Mode 4) The 4-20ma (0-10V) setpoint.	4.5 – 104.4 °C (40 - 220 °F)
nvoStackTemp	SNVT_temp_p  697	Stack temperature. Available only on PVC firmware version.	-46.1 – 132.7 °C (-51 – 271 °F)

## APPENDIX A – Status Flags

### BoilerStatus1 Flags

Bit	Description	Valid Values/Range
0	Disabled Boiler is disabled. For example, when minimum off time has not been met.	0 = enabled, 1 = disabled
1	Local Override (member boilers only)	0 = no override, 1 =override
2	Alarm An alarm or warning condition has occurred. An attempt(s) will automatically be made to recover and resume normal operation.	0 = ok, 1 = alarm
3	Failed A condition has occurred under which the boiler can no longer run.	0 = ok, 1 = failed
4	Member Error An "Alarm" or "Failed" condition has occurred on one (or more) of the member boilers.	0 = ok, 1 = error
5	Boiler Running	0 = off, 1 = on (running)
6	Local Pump Running	0 = off, 1 = on (running)
7	System Water Prove (Flow) Interlock. This input was previously called "Spare 3".	0 = open, 1 = closed
8	LWCO Interlock (Low Water Cut Off)	0 = open, 1 = closed
9	VFD Interlock (Variable Frequency Drive)	0 = open, 1 = closed
10	Gas Prove Interlock	0 = open, 1 = closed
11	Spare 4 (User) Interlock	0 = open, 1 = closed
12	Operator Interlock	0 = open, 1 = closed
13	Local Water Prove (Flow) Interlock	0 = open, 1 = closed
14	UV Sensor Air Prove Interlock	0 = open, 1 = closed
15	Main Valve	0 = closed, 1 = open

## BoilerStatus2 Flags

Bit	Description	Valid Values/Range
0	Pilot Valve	0 = closed, 1 = open
1	Blower Running	0 = off, 1 = on (running)
2	Ignition Alarm	0 = ok, 1 = alarm
3	IRI Alarm	0 = ok, 1 = alarm
4	High Limit	0 = ok, 1 = tripped
5	Air Prove Switch	0 = proven, 1 = not proven
6	---	---
7	Software Operator Tripped	0 = not tripped, 1 = tripped
8	Header Sensor not detected	0 = detected, 1 = not detected
9	Supply Sensor not detected	0 = detected, 1 = not detected
10	Return Sensor not detected	0 = detected, 1 = not detected
11	Outside Sensor not detected	0 = detected, 1 = not detected
12	System Pump Running	0 = off, 1 = on (running)
13	Combustion Air Damper Prove (J10B). Obsolete – available only on revision 1.x controls.	0 = not proven, 1 = proven
14	Master Boiler	0 = member, 1 = master
15	Boiler Detected  A boiler was detected at this address.	0 = not detected, 1 = detected

## BoilerStatus3 Flags

Bit	Description	Valid Values/Range
0	AA High Fire Input	0 = off, 1 = on
1	Heat Demand Input (Local Override)	0 = off, 1 = on
2	4-20ma Remote Enable Input	0 = off, 1 = on
3	Outdoor Air Reset Override Input	0 = off, 1 = on
4	T1 Input	0 = off, 1 = on
5	T2 Input	0 = off, 1 = on
6	T3 Input	0 = off, 1 = on
7	T4 Input	0 = off, 1 = on
8	---	---
9	---	---
10	---	---
11	---	---
12	---	---
13	---	---
14	---	---
15	---	---

## BoilerStatus4 Flags

Bit	Description	Valid Values/Range
0	DHW Enabled (1) DHW Mode had been enabled in the menus.	0 = off, 1 = on (menu)
1	Combustion Air Damper Prove (1) Status of Damper Prove Input J12B	0 = not proven, 1 = proven
2	Call Service Fault (1)	0 = ok, 1 = fault
3	Air Switch (Blower Fault) (1)	0 = ok, 1 = fault
4	---	---
5	---	---
6	---	---
7	---	---
8	---	---
9	DHW Sensor not detected (1)	0 = detected, 1 = not detected
10	DHW Boiler (1) This control board has been designated a DHW boiler by cutting the DHW jumper (JPS1).	0 = no, 1 = yes (DHW jumper cut)
11	Operating Limit Clamp (1) Boiler input is being limited (clamped) due to a high supply (outlet) temperature.	0 = off, 1 = clamped
12	---	---
13	---	---
14	---	---
15	---	---

(1) Available in Firmware Version 3.38+ and Bridge Configuration 2.30+.