

SUBMITTAL COVER SHEET

JJM BOILER WORKS, INC. / CONDENSATE Ph TREATMENT PRODUCTS

PROJECT NAME:

LOCATION:

ARCHITECT:

ENGINEER:

CONTRACTOR:

SUBMITTED BY:

DATE:

MODEL SUMMARY

Quantity				
Model	NBT-230			
Part #	2011			
Rating BTU	2000-3500 MBH			
Rating GPH	26.0 GPH Max			
Inlet Port Size	.75" Socket or Barb			
Outlet Port Size	.75" Socket or Barb			
Clear Cover	Yes			
PP Tank	Yes			
Light Grey Tank	Yes			
Voltage	N/A			
Amps	N/A			
Watts	N/A			
Pump rating GPM	N/A			
pH Panel Model	Walchem	N/A		
Pump panel	Heatimer			

Model		N/A		
Tube Material	PVC Sch40	N/A		
Tank Material	Polypropylene	Yes		
Tank Temperature Rating	140F Con.	Yes		
Tank Temperature Rating	140F Con.	Yes		
Tank Frames	Powder coated	N/A	N/A	
Mounting	Horizontal Floor	Yes		
Boiler, Hot water heater, furnace, flue stack, economizer, condensate drains	Yes			
Common Stack / Boiler	Yes			

NOTES:

Recommended Piping: Sch40 PVC, CPVC, Stainless Steel
Poly stranded Tubing with clamps

Submitted By:

